



Product Service

Attestation of Conformity

No. D6 15 06 92361 002

Holder of Attestation: **SANBRA FYFFE LTD**
CONEX WORKS, SANTRY AVENUE
9 DUBLIN
IRELAND

Product: **Circulation pump**

Model(s): **RS 25/6EA**

Parameters:

Rated voltage:	220-240VAC
Rated frequency:	50Hz
Rated input power	45W
Protection class:	I
Degree of protection:	IP 44
Rated head:	3.8 m
Rated flow:	2.0 m ³ /h
Declared EEI:	Less than 0.20

Implementation Measure EC Regulation
No 641/2009: 22.07.2009
Amended By EC Regulation
622/2012: 11.07.2012 and 2013/C 254/04: 04.09.2013
Stage 2 (01 Aug. 2015)

Tested according to: PPP 11093C:2013
EN 16297-1:2012
EN 16297-2:2012
EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the sample submitted to TÜV SÜD PRODUCT SERVICE GMBH for testing and evaluation and to its technical documentation. See also notes overleaf.

Test report no.: 701281512201-00

Date, 2015-06-15 (Jianying Lu)



Page 1 of 1